

Data Sheet

Half Squat 4-10









Half Squat 4-10

The perfect tradies companion, the SUMO Half Squat 4 is the most compact DB on the market. Available in 4 x 10A or 4 x 15A outlet configurations.



Voltage (Un)

230V

Weight (Kg's)

3 KGs

	Dimensions
	375 (L) x 230 (W) x 155 (H)

\bigvee	Rated Operational Voltage (UIMP)
	230V

Mary Mary	Humidity
	95% at 25C

70	Rated Impulse Withstand Voltage (UIMP)
	6kV

5D	Rated Short-Circuit Current (ICC)
C	3 PHASES (ICC): 10kA

Rated Frequency	Compliant	Installation Location
50-60Hz	AS/NZS 3190 AND AS/NZS 3012	INDOOR / OUTDOOR
Unit Classification	Connection	Breaker
PSOA	10A 56 series 3 Pin Plug with 1.8m Lead	NB1L - C10 - 10kA
IP Rating	Outlet Configuration	Class
IP66	4 x 10A 3 pin Auto-switched Outlet	Class C





Testing Procedure (Daily/Before Use)

- 1. Visual inspection:
- ·The visual inspection should be made before the distribution board is placed in service.
- ·Visual inspection of protection against direct contact with live parts e.g. insulation and enclosure.
- ·Visual inspection of lead and plug to ensure no damage to insulation or body work of plug that could impair safe operation.
- 2. Operation of automatic disconnection:
- •Correct operation of RCD's should be tested daily before use by pushing the test button and ensuring automatic disconnection of supply in the event of a fault.

Testing Procedure (Regular Intervals)

Electrical testing of this distribution board shall be carried out as stipulated in your state/territory/workplace procedures by a qualified electrician as according to AS/NZS 3000 Section 8. Testing shall be carried out in such a manner that the safety of the operator and other people in the vicinity, and test equipment is not placed at risk.

As stated in AS/NZS 3000 clause 8.3.3, a qualified electrician shall test in this order:

1.Continuity of the earthing system (earth resistance of the main earthing conductor, protective earthing conductors, PEN conductors and bonding conductors). in accordance with

Clause 8.3.5.

- 2.Insulation resistance, in accordance with Clause 8.3.6.
- 3. Polarity, in accordance with Clause 8.3.7.
- 4. Correct circuit connections, in accordance with Clause 8.3.8.
- 5. Verification of impedance required for automatic disconnection of supply (earth fault-loop impedance), in accordance with Clause 8.3.9.
- $\hbox{6.} Operation of RCDs, in accordance with Clause 8.3.10. \\$

Note:

- •The device shall not be used if it fails to operate correctly in accordance with the instructions provided.
- ·Warning! Do not store/use outside the service conditions. Do not misuse. Do not drop. Do not immerse in water or other liquid.
- ·The device will protect against faults to earth through the body, but not against active to neutral faults.
- •Electricity can be dangerous. The use of an RCD should not be regarded as a substitute for basic electrical safety precautions.
- ·User must unplug equipment to achieve isolation before any inspection or repair of the equipment is attempted.
- ·Warning! Please seek advice from an electrical contractor or the manufacturer if the RCD repeatedly trips, or if it fails to trip when tested in accordance with instructions.
- •The PRCD should be connected directly into a socket-outlet where possible. Supply by cord-extension sets may alter correct function
- If the supply cord is damaged, it must be replaced by the manufacturer, its service agent or similarly qualified persons in order to avoid a hazard.































GENERATORS 6KVA - 1500KVA



STANDBY



STATIONARY



MOBILE



TRAILER



CONTAINER



HEAVY DUTY



BIG TANK



WHISPER



WHISPER BIG TANK



INVERTER

FUEL CELLS 1KL - 100KL



LIFT & SHIFT



STATIC STORAGE



TOW TANKS



BULK STORAGE



SMARTS

DISTRIBUTION 10A - 1000A



HANDHELD



СОМВО



STACKABLE



MASTER BOARD



LOAD BANKS

RENEWABLE RANGE





BATTERY



HYDROGEN



CONTAINER BATTERY



FILTERS

